

Asset Repair History Report

Asset Information

Asset Name:
Generator Model X1500

Asset ID / Serial No.:
GENX1500-2020198

Location:
Power House, Plant 1

Department:
Maintenance

Manufacturer:
PowerGen Solutions

Date Commissioned:
2019-07-18

Repair History

Date	Repair Description	Parts Replaced	Performed By	Cost (USD)	Remarks
2023-11-12	Fuel pump replacement	Fuel Pump (FP-203), Filter	John Miller	420	Restored normal function
2022-08-06	Routine service, oil change	Engine Oil, Oil Filter	Amanda Lee	120	Serviced on time
2021-03-19	Alternator repair	Alternator Assembly	Tom Sawyer	650	Tested post repair

Summary

Total Number of Repairs:
3

Total Repair Cost (USD):
1,190

Current Asset Status:
Operational

Important Notes:

- Ensure all repairs and maintenance are recorded immediately after completion.
- Attach relevant invoices and technician reports for each repair entry.
- Review repair history regularly to identify recurrent issues and plan preventive maintenance.
- Asset status should be updated after every significant repair or inspection.
- Maintain accuracy in costs and part details for audit and budgeting purposes.